



WebdynSunPM  
Annex

# Known Issues



## Known Issues

### Note

This list is built to inform users about common ongoing issues which is actively tracked. This list is non-exhaustive.

**3457** - All SunSpec equipments are categorized Inverters

- **Detection** : 5.1.07

**3939** - SunSpec detection is more restricting, leading to unsuccessful detection

- **Detection** : 5.1.01

**3967** - Retrieving certificate from SFTP

- **Detection** : 5.1.00

**3969** - Custom domain with AWS MQTTS is not working

- **Detection** : 5.1.00

**3991** - Manually filled device serial number is not kept in <uid>\_daq.csv

- **Detection** : 5.1.04

**3997** - Missing device tag when adding a device manually or through automatic detection

- **Detection** : 5.1.01

**3999** - SMS command updatefirmware is not working with SFTP

- **Detection**: 5.1.05

**4000** - Name of device using SMA net proprietary protocol can't be changed in the embedded web server

- **Detection**: 5.1.05

**4001** - log command from command file is not working on SFTP/FTP

- **Detection** : 5.1.05